

**OVE AUSTRIAN ELECTROTECHNICAL ASSOCIATION**

Eschenbachgasse 9, 1010 Wien, Austria  
ZVR: 327279890 | DVR: 1055887

**OVE - Testing & Certification**

Kahlenberger Str. 2A, 1190 Wien, Austria  
Phone: +43 1 370 58 06  
www.ove.at



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **51923-013-00**

Valid from: 2016 03 31  
until: 2018 03 31

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **BUDVILL es Tsa Kft.**  
Körtvelyes u. 12/a  
1037 Budapest  
Hungary

Product: **Cable duct for mounting on walls and ceilings**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 36593**

**Österreichischer Verband für Elektrotechnik**  
Head of Testing & Certification

Digitally signed by W. Martin  
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Vienna, 2016 03 31



**OVE - Testing & Certification**

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under [www.en.bmwf.gv.at/accreditation](http://www.en.bmwf.gv.at/accreditation)





**Manufacturer:**

BUDVILL es Tsa Kft.  
Fehéritögyár utca 2  
1037 Budapest  
Hungary

**Factory location(s):**

BUDVILL es Tsa Kft.  
Fehéritögyár utca 2  
1037 Budapest  
Hungary

**Tested and certified according to:**

ÖVE/ÖNORM EN 50085-1:2014-06-01  
ÖVE/ÖNORM EN 50085-2-1:2012-10-01

This certificate is the basis for the EC Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EC Low-Voltage Directive**.

**Product: Cable duct for mounting on walls and ceilings**

**Type designation:**

**Rating:**

**Trademark:**

**KR2540**

Rated voltage: 400 V  
Type 1; IP20  
Application temperature: -15 °C to +90 °C  
Resistance to impact: 1J  
non-flame propagating  
white, grey, brown

BUDVILL

**K64**

Rated voltage: 400 V  
Type 1; IP20  
Application temperature: -15 °C to +90 °C  
Resistance to impact: 1J  
non-flame propagating  
white, grey, brown

BUDVILL

**OVE - Testing & Certification**

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under [www.en.bmfwf.gv.at/accreditation](http://www.en.bmfwf.gv.at/accreditation)

